

**American Society of Sanitary Engineering
Seal (Certification) Program**

**Factory Audit Inspection Test for:
Trap Seal Primer Valves - Drainage Types and Electronic Design Types**

**Tested for compliance to ASSE Standard #1044
Revised: February, 2001**

Manufacturer _____

Model No. _____

Address _____

Serial No. _____

Other Identification Markings _____

Connections (screwed, etc.) _____

Low Pressure

3.1 Hydrostatic Test for Ballcock, Flushometer and Fixture Tailpiece Devices

What was the maximum pressure applied? _____ kPa (_____ psi)

How long was the pressure sustained? _____ minutes

Were there any indications of damage or leakage? Yes No

3.3 Verification of Manufacturer's Performance Rating

Did the manufacturer furnish ratings for the four types of devices? Yes No

List the quantities below:

Minimum flow rates through the supply line. _____ L/m (_____ GPM)

Minimum flow rates to the trap seal. _____ L/m (_____ GPM)

High Pressure

3.2 Electronic Devices

What was the maximum pressure? _____ kPa (_____ psi)

How long was the pressure applied? _____ minutes

Were there indications of damage or leakage? Yes No

3.4 Cycle Test for Electronic Devices

Pressurize the device to 345 kPa (50 psi), and active the device for a 5,000 cycles.

Were there any indications of damage or leakage? Yes No

Was the device in compliance with this section? Yes No

TESTING AGENCY _____

ADDRESS _____

PHONE: _____ FAX: _____

TEST ENGINEER(S) _____


We certify that the evaluations are based on our best judgments and that the test data recorded is an accurate record of the performance of the device on test.

Signature of the official of the agency: _____

Title of the official: _____ Date: _____

Signature and seal of the Registered Professional Engineer supervising the laboratory evaluation:

Signature



Seal