

**American Society of Sanitary Engineering
Seal (Certification) Program**

**Factory Audit Inspection Test for:
Air Valve and Vent Inflow Preventer**

**Tested under ASSE Standard 1063
Factory Audit Inspection Test**

Manufacturer _____

Model No. _____

Address _____

Serial No. _____

Other Identification Markings _____

Size _____

Connections (screwed, flanged, etc.) _____

3.1 Hydrostatic Pressure Testing of Complete Device

What water pressure was used for this test? _____ psi (_____ kPa)

What was the temperature of the water used for this test? _____ °F (_____ °C)

The pressure test period was for _____ minutes.

Were there any leaks through the body or flanges or any indication of damage to the assembly?

- Yes
- No

In compliance?

- Yes
- No

3.2 Water Tightness Test of Float Operated Checks

Was the assembly installed in a test apparatus as shown in Figure 2?

- Yes
- No

Was the procedure followed for both the #1 and #2 float checks?

- Yes
- No

Observation time for each check: _____ minutes

Was there a drop in the water column height greater than 1/8" (3.2 mm) for either seat test?

Yes

No

In compliance?

Yes

No

TESTING AGENCY _____

ADDRESS _____

PHONE: _____ FAX: _____

TEST ENGINEER(S) _____


We certify that the evaluations are based on our best judgments and that the test data recorded is an accurate record of the performance of the device on test.

Signature of the official of the agency: _____

Title of the official: _____ Date: _____

Signature and seal of the Registered Professional Engineer
supervising the laboratory evaluation:

Signature



Seal