

**American Society of Sanitary Engineering
Seal (Certification) Program**

**Factory Audit Inspection Test for:
Dielectric Pipe Unions**

Tested in accordance with ASSE Standard #1079 • ASSE: 2005

Manufacturer _____

Model No. _____

Address _____

Serial No _____

Other Identification Markings _____

Size _____

3.0 Performance and Compliance Testing

3.1 Hydrostatic Test

What was the pressure used for this test? _____ psi (_____ kPa)

The pressure was applied for _____ minutes.

In compliance?

- Yes
 No

3.2 Dielectric Test

What was the measure of micro amps at a voltage of 600 AC? _____

What was the measure of micro amps at a voltage of 2000 DC? _____

In compliance?

- Yes
 No
 Questionable

If questionable, explain: _____

TESTING AGENCY _____

ADDRESS _____

PHONE: _____ FAX: _____

TEST ENGINEER(S) _____


We certify that the evaluations are based on our best judgments and that the test data recorded is an accurate record of the performance of the device on test.

Signature of the official of the agency: _____

Title of the official: _____ Date: _____

Signature and seal of the Registered Professional Engineer
supervising the laboratory evaluation:

Signature



Seal